

MT. SAN JACINTO COMMUNITY COLLEGE DISTRICT
ADDENDUM NO. 2
BID NO.2020-017
CONSTRUCTION OF SHADE STRUCTURES
AT THE SAN JACINTO CAMPUS

May 12, 2020

Owner:

Mt. San Jacinto Community College District
1499 N. State Street
San Jacinto, CA 92583

Addendum No. 2

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PROPOSAL WHEN SUBMITTED

Questions

- Q1. Is there an allowance to the project that the bidders need to include in their proposal?
- A1. There is no allowance.
- Q3. Are subcontractors also required to be prequalified or just prime contractors?
- A3. Only Prime Contractors need to be prequalified.
- Q4. Per Plan page AS-1-3 Keynote 2-7 – patch and repair athletic surface as required. Please advise what the existing surface is (material or manufacture)?
- A4. Existing material is assumed to be textured acrylic surfacing. For bidding purposes, provide Plexipave System as manufactured by California Products Corp. or approved equal for patching areas. Color to match existing surfaces.
- Q5. Please clarify who is responsible for the shade structures and footings?
- A5. See addendum #1: The District has an existing contract with USA Shade to manufacture and install the shade structure elements.

General

Underground Utility Survey – See attached link:

<https://www.dropbox.com/s/nttkatt25l2yahd/19-1650%20Main%20Utility%20Map%204.10.2020.zip?dl=0>